INSPECTION CHECKLIST

This is a checklist provided for your convenience, and DOES NOT mean other items not listed will not be found.

- THE FOLLOWING MUST BE PROVIDED BY YOU BEFORE A CERTIFICATE OF OCCUPANCY CAN BE ISSUED: Provide proof (dated receipt signed by the technician) of inspection of furnace by a licensed heating contractor.
- 2. Three grounded outlets in kitchen.
- 3. All plugs in bathroom must be G.F.I.
- 4. Stairwells between floors to have a 3-way switch
- 5. Minimum 100 amp service is required
- 6. Bond water meter/run ground wire to water meter from panel
- 7. All wiring must be to code. (Covers on all junction boxes, outlets and switches)
- 8. Any unused wiring must be removed.
- 9. Bathroom with no operable window must have a working exhaust fan.
- 10. Smoke alarms must be installed in every bedroom, near sleeping area, on each level and within 3 feet if basement stairs.
- 11. Provide A.G.A approved valves for water heater, furnace and dryer
- 12. Concrete must not have any trip hazards (Including City Sidewalk)
- 13. Handrails must be in place and secure at all stairways with return ends.
- 14. Front and Rear porch/deck require handrails and guardrails.
- 15. Replace any missing screens
- 16. Replace any cracked or broken windows
- 17. All doors to work properly with good working hardware
- 18. Provide vacuum breakers on laundry tub and all exterior hose bibs.
- 19. Reglaze or repair chips in bathtub and sink
- 20. Hand-held shower requires vacuum breaker or be replaced with a fixed shower head.

IF INSPECTOR IS UNABLE TO ENTER ADDRESS FOR ANY SCHEDULED IINSPECTIONAN ADDITIONAL \$40 FEE FOR EACH INSPECTOR WILL BE REQUIRED BEFORE NEXT INSPECTION. ALL REQUIRED PERMITS MUST BE PULLED BEFORE CERTIFICATE OF OCCUPANCY WILL BE ISSUED.